

NewTechWood Ltd.

TEST REPORT

SCOPE OF WORK

NewTechWood UltraShield

REPORT NUMBER

191219007SHF-001

TEST DATE(S)

2019-12-20 - 2020-01-07

ISSUE DATE

2020-01-07

PAGES


5

DOCUMENT CONTROL NUMBER

LFT-APAC-SHF-OP-10k(May 1, 2019)

© 2020 INTERTEK

Intertek Testing Services Shenzhen Ltd. Shanghai Fengxian Branch



Test Report

Statement

- 1.This report is invalid without company's special seal for testing on assigned page.
- 2.This report is invalid without authorized person's signature.
- 3.This report is invalid where any unauthorized modification indicated.
- 4.Don't copy this report in partial (except full copy) without any official approval in written by our company. This report is invalid without re-stamping the special seal for testing in copying report.
- 5.Any holder of this document is advised that this report is for the exclusive use of Intertek's Customer and is provided pursuant to the agreement between Intertek and its Customer. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. This report was made with due care within the limitation of a defined scope of work and on the basis of information, materials and instructions received from the Customer or its nominated third parties. Intertek is under no obligation to refer to or report upon any facts or circumstances which are outside the specific instructions received and accepts no responsibility to any parties whatsoever, following the issue of the report, for any matters arising outside the agreed scope of the works. The tests results are not intended to be a recommendation for any particular course of action. Customer is responsible for acting as it sees fit on the basis of such results.
- 6.Intertek's written consent is required to use Intertek's name or logo on the object, product or service being tested. The observations and test results in this report relate only to the sample under test. This report alone does not indicate that the item, product or service has passed any Intertek certification program.

Test Report

Issue Date: 2020-01-07 Intertek Report No. 191219007SHF-001
Applicant: NewTechWood Ltd.
Address: 19111 Walden Forest Dr. Suite B Humble, Tx 77346, USA
Attn: Cliff Lam
Manufacturer : HUIDONG MEIXIN PLASTIC LUMBER PRODUCTS MANUFACTURING CO.,Ltd
Address : NGA INDUSTRIAL PARK , DALING , HUIDONG , GUANGDONG PROVINCE , PRC
Test Type : Performance test, samples provided by the applicant.

Product Information

Product Name	NewTechWood UltraShield	Brand	/
Sample Description	Good Condition	Sample Amount	1 package
		Received Date	2019-12-19
Sample ID	Model	Specification	
S191219007SHF.001	NewTechWood UltraShield UH02	138.00*22.50mm	


Test Methods And Standards

Test Standard	EN 1815:2016, Method A
Specification Standard	/
Test Conclusion	The samples were tested according to the above standards, and the results are shown in the following page.

Note:

1.This report relates specifically to the sample(s) that were drawn and provided by the applicant or their nominated third party. The reported result(s) provide no warranty or verification on the sample(s) representing any specific goods and/or shipment and only relate to the sample(s) as received and tested.

Report Authorized



 Name: Flora Fan Name: Torres Qi
 Title: Reviewer Title: Project Engineer

Test Report

Issue Date: 2020-01-07

Intertek Report No. 191219007SHF-001

Test Items, Method and Results:

Test Item: The body voltage (Static electrical propensity)

Test Method: EN 1815:2016, Method A - Test procedure in laboratory conditions

Conditioning: Condition the test specimens at (23±2)°C and (25±2)% relative humidity for at least 7 days

Test Condition:

Temperature: 23±2 °C

Relative humidity: 25±2 %

Substructure: A earthed metal base plate

Material of the sandal sole: Rubber

Test Result: 1.0 kV

Test Report

Issue Date: 2020-01-07

Intertek Report No. 191219007SHF-001

Appendix A: Sample Received Photo



Surface view



Section view

Revision:

NO.	Date	Changes	Author	Reviewer
191219007SHF-001	2020-01-07	First issue	Torres Qi	Flora Fan