TEST REPORT

No. : GZIN1905024755CM
Date : Jun 03, 2019

GZIN1905024755CM

CUSTOMER NAME:		NEWTECHWOOD LTD.
ADDRESS:		19111 WALDEN FOREST DR. SUITE B HUMBLE, TX77346, USA
Sample Name	:	NewTechWood UltraShield UH02(TK)
Product Specification	:	138.00mm*22.50mm
Manufacturer	:	HUIDONG MEIXIN PLASTIC LUMBER PRODUCTS MANUFACTURING CO., LTD

Above information and sample(s) was/were submitted and confirmed by the client. SGS, however, assumes no responsibility to verify the accuracy, adequacy and completeness of the sample information provided by client.

****

Date of Receipt	:	May 20, 2019
Testing Start Date	:	May 20, 2019
Testing End Date	:	Jun 03, 2019
Test result(s)	:	For further details, please refer to the following page(s) (Unless otherwise stated the results shown in this test report refer only to the sample(s) tested)

Signed for
SGS-CSTC Standards Technical Services Co., Ltd. GZ Branch Testing Center

Tobby Yang
Authorized signatory

Unless otherwise agreed in writing, this document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at http://www.sgs.com/en/Terms-and-Conditions.aspx and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at http://www.sgs.com/en/Terms-and-Conditions/Terms-e-Document.aspx. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for 30 days only.
Attention:To check the authenticity of testing / inspection report & certificate, please contact us at telephone:(86-755) 8307 1443, or email: CN.Doccheck@sgs.com
198 Kezhu Road, Scientech Park, Economic & Technical Development District, Guangzhou, China. 510663 t (86-20) 82155555 f (86-20) 82075080 www.sgsgroup.com.cn
中国・广州・经济技术开发区科学城科珠路198号 邮编: 510663 t (86-20) 82155555 f (86-20) 82075080 e sgs.china@sgs.com
Member of the SGS Group (SGS SA)

TEST REPORT

Slip resistance (oil-wet ramp test)

Test Method:

DIN 51130:2014-02 Testing of floor coverings - Determination of the anti-slip property - Workrooms and fields of activities with slip danger, walking method - Ramp test

Sample Description:

Flooring, see the photo(s)

① Long side direction: 1000mm×135mm, 3pcs, cut from original sample, form a testing surface of 1000mm×405mm

② Short side direction: 500mm×135mm, 6pcs, cut from original sample, form a testing surface of 500mm×810mm

Test Result:

Testing direction & testing surface: see the photo(s)

Test item(s)	Test result(s)	Classification
Slip resistance (oil-wet ramp test)	(Long side direction) Critical angle of inclination:10.9°	R10
	(Short side direction) Critical angle of inclination:13.0°	R10

Classification of oil-wet ramp test:

Classification	Angle (degrees)
R9	6°≤X≤10°
R10	10°<X≤19°
R11	19°<X≤27°
R12	27°<X≤35°
R13	>35°

******** To be continued********

Unless otherwise agreed in writing, this document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at http://www.sgs.com/en/Terms-and-Conditions.aspx and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at http://www.sgs.com/en/Terms-and-Conditions/Terms-e-Document.aspx. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for 30 days only.
Attention:To check the authenticity of testing / inspection report & certificate, please contact us at telephone:(86-755) 8307 1443, or email: CN.Doccheck@sgs.com

198 Kezhu Road, Scientech Park, Economic & Technical Development District, Guangzhou, China. 510663 t (86-20) 82155555 f (86-20) 82075080 www.sgsgroup.com.cn
中国·广州·经济技术开发区科学城科珠路198号 邮编: 510663 t (86-20) 82155555 f (86-20) 82075080 e sgs.china@sgs.com

Member of the SGS Group (SGS SA)

TEST REPORT

No. : GZIN1905024755CM
Date : Jun 03, 2019

Specimen photograph(s):

Original sample(s)

SGS authenticate the photo(s) on original report only

Note: The above test was carried out by SGS-CSTC Standards Technical Services Co., Ltd. Xiamen Branch.

******** End of report********

Unless otherwise agreed in writing, this document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at http://www.sgs.com/en/Terms-and-Conditions.aspx and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at http://www.sgs.com/en/Terms-and-Conditions/Terms-e-Document.aspx. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for 30 days only.
Attention:To check the authenticity of testing / inspection report & certificate, please contact us at telephone:(86-755) 8307 1443, or email: CN.Doccheck@sgs.com

198 Kezhu Road, Scientech Park, Economic & Technical Development District, Guangzhou, China. 510663 t (86-20) 82155555 f (86-20) 82075080 www.sgsgroup.com.cn
中国·广州·经济技术开发区科学城科珠路198号 邮编: 510663 t (86-20) 82155555 f (86-20) 82075080 e sgs.china@sgs.com

Member of the SGS Group (SGS SA)